

BRAWLEY UNION HIGH SCHOOL DISTRICT

480 NORTH IMPERIAL AVENUE, BRAWLEY, CA 92227 * (760) 312-5819 * FAX (760) 344-9520 * <http://www.brawleyhigh.org>

“Excellence is Our Standard”

SIMON R. CANALEZ
Superintendent



REQUEST FOR PROPOSALS BUHSD RFP #2019-01 Network Equipment YR22 (2019/2020) 12.20.2018

This Addendum is issued to clarify the previously issued RFP and/or given for informational purposes, and is hereby made part of the Bid documents. Please attach this addendum to the documents in your possession. Per the RFP, the proposer shall acknowledge receipt of any and all addenda, if any, listing the addenda by number(s) and date(s) in their letter of interest or proposal.

In the case of conflict between RFP and any applicable documents this Addendum shall govern.

Let it be known on pages 15-17 under section B “UPS and Installation” of the District issued RFP that the following specification “**Zero transfer time to battery**” under Type 1 and Type 2 for UPS will be **REMOVED** from this RFP as it was Inadvertently listed.

1. Type1. MDF Location/Quantity =3
 - 120, 208, 240 Volt Nominal AC Input
 - 120, 240 Volt Nominal AC Output
 - 8000+VA – 8000+W
 - True On-Line, Double-Conversion operation
 - Pure Sine Wave Output
 - ~~Zero Transfer time to Battery~~
 - Hot-swappable power and battery modules
 - Step Down Transformer
 - Fault Tolerant automatic bypass
 - Surge Suppression
 - Minimum 8 Nema 5-15 receptacle
 - Power Management Software
 - Network card for advanced management
 - Rack Mountable
 - 2+ Years Warranty
 - Installation

2. Type 2. IDF Location/Quantity = 35
 - 120 Volt Nominal AC Input
 - 120 Volt Nominal AC Output
 - 1500VA – 1000+W
 - Line Interactive
 - Pure Sine Wave Output
 - ~~Zero Transfer time to Battery~~
 - Automatic Voltage Regulation
 - Surge Protection

BRAWLEY UNION HIGH SCHOOL DISTRICT BOARD OF TRUSTEES

Patricia Wilson Rosendo (Rusty) Garcia Gabriel Contreras Carol Sassie Karin Morgan
Brawley Union High School District is an affirmative action equal opportunity employer

- Minimum 6 Nema 5-15 receptacle
- Rack Mountable, 1 or 2U
- 2+ Years Warranty

Installation

Although this change in scope may be considered a Cardinal Change and would require a restart of the 28 days (Allowable Contract Date) by USAC, the RFP due date will remain 1/22/2019 by 3:00 p.m. PST as it still falls within the allowable timeframe.

“END OF ADDENDUM”